

# CERTIFICATE OF COMPLIANCE

**Certificate Number** EX26915  
**Report Reference** EX26915- 20160119  
**Issue Date** 2020-FEBRUARY-25

**Issued to:** Liberty Ostrava a.s.  
Vratimovska 689 719 00 Ostrava - Kuncice CZECH  
REPUBLIC

**This certificate confirms that  
representative samples of** METALLIC SPRINKLER PIPE  
See next page for Models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 852, Metallic Sprinkler Pipe for Fire Protection Service  
ULC/ORD C199S, Light Wall Steel Pipes for Sprinkler  
Systems for Fire Protection Service

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

Certificate Number EX26915  
Report Reference EX26915- 20160119  
Issue Date 2020-FEBRUARY-25

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## PRODUCT COVERED:

USL, CNL – Metallic Sprinkler Pipe (VIZY, VIZY7)

Schedule 40 steel sprinkler pipe for wet, dry, preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or Listed Rubber Gasketed Fittings when installed in accordance with the fitting manufacturer's specifications.

Schedule 40 steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, and 10 inch sizes



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

